

close print

Brand: **Candlewood Suites**

Scheme: Scheme C - Tempo

Area: Guest Rooms

Category: WindowTreatments

Item: Drapery

Item Code: GRC-610

Vendor: Quiltcraft

Model: 2-way Draw - See Notes

Description: Guestroom Window Treatment (with PTAC)

Pattern:

Color:

Style:

Specifications:

DESCRIPTION: Fabrication of Lined Stationary Side Panels, Blackout Drapery & Sheer at Guestrooms with PTAC Unit (also used in Tele/Video Room)

NOTES:

1. Guestroom window treatment fabrication. Refer to Note #8 for window treatment descriptions.
2. Drapery sizes and quantities to be verified at each property.
3. All drapery and sheers to include 30" front-mount fiberglass batons at typical rooms (48" batons at ADA rooms), 200% fullness, French pleat style, 4" double heading, 4" double hem, 1½" double side hem.
4. Window treatments must be fabricated in a manner that precludes light leakage or transfer of light ("Z" fold bottom hem, etc.). Window treatments must have sufficient overlap at center, and sufficient return at sides to preclude light transfer/view.
5. Buckram must be triple dip and washable, 1" covered lead weights tacked at hemline on each seam except directly above PTAC units- covered weight strip must be used across entire hem of the sheer to prevent blowing. Drapery pin hooks to be stainless steel.
6. Pattern must be matched at seams; seams must be hidden within pleats.
7. Length of sheer should not exceed the length of the blackout drapery.
8. Drapery Lot to include the following:

Stationary Side Panel:


- Fabrication to consist of two 18" wide stationary side panels plus 9" returns, lined with 2-Pass blackout FR Grey/White lining. Side panels to flank the window and not cover any glass if possible. Panels should be ceiling mounted and extend to the floor with approximately 1" clearance off the floor. (Per manufacturer fabric passes NFPA-701. Manufacturer to submit flame certificate to purchasing agent for client's records).

Blackout Drapery:

- 2-way draw, 3-Pass White/White blackout drapery. Blackout drapery should be ceiling mounted and extend 1"-2" below the window sill. (Per manufacturer fabric passes NFPA-701. Manufacturer to submit flame certificate to purchasing agent for client's records).
- Ceiling mounted hardware to be Kirsch Architrac #94004, color white or equal.

Sheer Drapery:

- 2-way draw (Vendor supplied batiste marble fire retardant sheer) sheer drapery. Sheer should be ceiling mounted and extend 1" – 2" below the window sill.
- Ceiling mounted hardware to be Kirsch Architrac #94004, color white or equal.



\$ *****
\$ *****

Vendor Contact:

Quiltcraft
1230 East Ledbetter

Dallas, TX 75216-6988
USA

David Pearson
Sales Associate
TEL: 214-376-1841
FAX: 214-376-1852
dpearson@quiltcraft.com

Prices above do not include taxes, shipping, or installation costs unless otherwise stated. All installed fabrics, upholstery, carpet, wall covering and other finish materials must meet local fire codes and regulations; Owner and Purchasing Agent must provide all code information to manufacturer. Fabricator and/or installer must confirm exact quantities required. Manufacturers must provide maintenance instructions.

9. Drapery fabrication must be of contract quality and suitable for commercial use.

See [Candlewood Suites Window Treatment Preamble](#) for additional general construction and guidelines.

Fabric at Drapery:

Manufacturer: [Hunter Douglas Hospitality/Richmond Textiles](#)

Model/Style No.: Pattern: Strata, Base Cloth: Ambrose.
Color: Custom #6059
Content: 100% Polyester Avora FR Blend
Dimensions/Repeat: 55"-57"W / 4.5" Vertical, 6.75" Horizontal

1. Drapery manufacturer to verify all yardages prior to fabric order.
2. Per manufacturer, fabric is inherently flame resistant, and meets NFPA-701 for drapery.
3. Fabric must be of contract quality and suitable for commercial use.

Last Update: 2010-01-25, Original Issue: 2005-04-15 ID:1684